

Thermo-Economic Analysis of Four sCO₂ Waste Heat Recovery Power Systems

Steven A. Wright

swright@supercriticaltech.com



Chal S. Davidson

cdavidson@supercriticaltech.com



William O. Scammell

bscammell@supercriticaltechnologies.com



Introduction

- **Goal: Provide A System Performance and Economic Analysis of Four Waste Heat Recovery sCO₂ power system**
- **Four WHR sCO₂ power systems:**
 - Simple Recuperated Brayton Cycle (SRBC)
 - Cascaded Cycle : Patented & WHR
 - Dual Recuperated Cycle: Patented & WHR
 - Preheating Cycle: Public & WHR
- **Assumptions**
 - Gas Turbine, M2500 extending EPRI Study by Kimzey
 - sCO₂ Bottoming Cycle Power Systems
 - Economic, Component Costs and Operating Conditions
- **Comparison of System Performance**
 - Focus: on Maximizing Annual Revenue = Electric Power Produced
 - Answers these questions:
 - Does It make economic sense to use HX's of High Effectiveness?
 - How do the publically available cycles compare to the commercially patented cycles?
- **Economic Summary**
 - (System Costs, Annual Revenue, LCOE, Rates of Return)
- **Conclusions**
 - All WHR have Higher Revenue, Lower LCOE, Produce Substantially Greater Elect Power
 - But at greater cost
 - As a group the WHR Perform Similarly in terms of Electrical Power and Economics
 - Recuperators with High Effectiveness are Generally Favored


Gas Turbine Assumptions

Primary Gas Turbine	LM-2500PE
Mass Flow Rate Gas Turbine	68.8 kg/s
Temp of Gas Turbine Exhaust	822.1 K
Efficiency (at Gen Terminals at 15 C ambient)	35.5%
Thermal Combustion Power (@ 10146 kW/ BTU/hr)	63,131 kW _{th}
Thermal Exhaust (Waste Heat) Power kW (@ 15 C)	40,731 kW _{th}

LM2500PE Gas Turbine




822.1 K
(538 C)
40.7 MW_{th}



Performance Optimization

Optimization Parameters


- Mass Flow Rate
- Turbine Inlet Temp
- dT_{approach} Recuperator Cold side
- dT_{approach} Recuperator Hot side
- dT_{approach} Prim HX
- Split Flow (if used)




+ Flow Split

Four sCO₂ Power Cycles


Simple Recuperated Brayton Cycle




Cascaded Cycle



Dual Recuperated Cycle



Preheating Cycle





All WHR sCO₂ Cycles Use Split Flow

Simple Recuperated Brayton Cycle

Simple Recuperated Brayton Cycle

Cycle Thermal Efficiency= 30.4% Net Cycle Efficiency= 28.3% Net Pwr 7017 kW

glide curve





Net Efficiency is $eff_{NET} = eff_{WHR} * eff_{CO2-mech} * eff_{mech-elec}$ (93%)

CG Exit Temp is Limited by Recup High Pressure Exit Temp: This is high (see glide curve)
 This lowers Waste Heat Recovery Efficiency $eff_{WHR} = (Q_{CO2} / Q_{WH}) = 61.2\%$
 Power Optimization Increases $eff_{CO2} = 30.4\%$

Cascade Cycle

glide curve

Cascaded Cycle





CG Exit Temp is now limited by Compressor Exit Temp: This is low (see glide curve)
 This Increases Waste Heat Recovery Efficiency $eff_{WHR} = (Q_{CO2}/Q_{WH})$ 85.6%
 Power Optimization with 2 Turbines and 2 Recup Increases $eff_{CO2} = 26.5\%$

Duel Recuperated Cycle

glide curve

Dual Recuperated sCO₂ WHR Power Cycle

Thermal Cycle Efficiency= 28.17% Net Cycle Efficiency= 26.2% Net Power 8322 kWe
Total Efficiency= 20.53%



CG Exit Temp is now limited by LT Recup Exit Temp This is intermediate (see glide curve)

This Increases Waste Heat Recovery Efficiency $eff_{WHR} = (Q_{CO2} / Q_{WH})$ 78.4%



Power Optimization with 2 Turbines and 2 Recup Increases $eff_{CO2} = 28.2\%$

sCO2 Preheating Cycle

glide curve

Simple Recuperated Brayton Cycle with Preheating for WHR

Thermal Cycle Efficiency = 27.80% Net Cycle Efficiency = 25.9% Net Pwr = 8601 kWe




CG Exit Temp is now limited by Compressor Exit Temp This is low (see glide curve)
 This Increases Waste Heat Recovery Efficiency $eff_{WHR} = (Q_{CO2}/Q_{WH})$ 82.1%
 Thermal Cycle Efficiency: $eff_{CO2} = 27.8\%$

Four sCO₂ Power Cycles


Simple Recuperated Brayton Cycle

- 1 Turbine
- 1 Compressor
- 1 Recuperator
- 1 CO₂ Chiller
- 1 Prim Hx
- 5 Components : No Split Flow




Cascaded Cycle

- 2 Turbines
- 1 Compressor
- 2 Recuperators
- 1 CO₂ Chiller
- 1 Prim Hx
- 7 Components + Split Flow




Dual Recuperated Cycle

- 2 Turbines
- 1 Compressor
- 2 Recuperators
- 1 CO₂ Chiller
- 1 Prim Hx
- 7 Components + Split Flow



Preheating Cycle

- 1 Turbines
- 1 Compressor
- 1 Recuperators
- 1 CO₂ Chiller
- 2 Prim Hx
- 6 Components + Split Flow



Economic Assumptions

Economic Assumptions	Value
Plant Lifetime	20 yr
Plant Utilization Factor	85%
Discount Rate	5%
Sale Price of Electricity	\$0.06/kWh _e
Thermal Exhaust (Waste Heat) Power kW (@ 15 C)	40,731 kW _{th}

+


Component Specific Costs

Component Costs

Dual Recuperated sCO2 WHR Power Cycle

Thermal Cycle Efficiency= 28.17% Net Cycle Efficiency= 26.2% Net Power 8322 kW
 Total Efficiency= 20.53%

Turbo Machinery + Aux
 Cost = $\text{SpecCost}_{\text{Turb+Aux}} * P_{\text{wr}_e}$




Primary Heater

Recuperators

CO2 Chillers

$$Q = U * A * \text{LMDT} \quad \text{Cost} = \text{SpecificCost}_{\text{HX}} * Q / \text{LMDT} = U * A$$

Component Specific Costs



Component Description	Cost Units	Component Specific Costs
Recuperators (cost/UA)	\$/((kW.th/K)	2500
Fin Tube Primary Heater (cost/UA)	\$/((kW.th/K)	5000
Tube and Shell CO ₂ -Chiller (cost/UA)	\$/((kW.th/K)	1700
Turbomachinery+Gen+Mtr+Gear+Piping+Skid+I&C+Aux.BOP	\$/kWe	1000

Summary of Results

		SRBC	Cascaded	Dual Recup	Preheating
LM-2500PE	Units				
Waste Heat (Brochure) LM2500	kW.th	40,731	40,731	40,731	40,731
Waste Heat Combustion Model	kW.th	40530	40530	40530	40530
Mass flow rate thru Comp	kg/s	93.2	124.6	112.8	121.4
Max flow rate in Heater	kg/s	93.18	56	64.49	121.4
Efficiency of WHR		61.2%	85.6%	78.4%	82.1%
Net SCO2 Cycle Efficiency		28.3%	24.7%	26.2%	25.9%
Total Efficiency		17.31%	21.13%	20.53%	21.22%
Max Turbine Inlet T	K	685.0	756.9	743.5	662.6
Max Turbine Inlet T (C)	C	411.8	483.8	470.3	389.5
Stack Exit Temp (K)	K	497.1	372	409.0	390.0
Stack Exit Temp (C)	C	223.9	99	135.9	116.8
Total UA	kW/K	1795	2807.98	2447	2966
Recup UA	kW/K	630.5	1036.96	782.8	1226.76
Heater UA	kW/K	446.6	837.58	794.1	740.71
Chiller UA	kW/K	718.2	933.45	870.4	998.97
Recup Costs	\$	1,576,314	2,592,403	1,957,006	3,066,890
Heater Costs	\$	2,232,836	4,187,885	3,970,675	3,703,565
Chiller Costs	\$	1,221,021	1,586,858	1,479,629	1,698,246
Total HX Costs		5,030,171	8,367,146	7,407,310	8,468,702
HEAT EXCHANGER EFFECTIVENESS					
Prim HT HX	%	94.6%	94.0%	95.0%	93.5%
Preheater HX	%				90.8%
HT Recup	%	94.0%	92.3%	83.1%	90.5%
LT Recup	%		88.4%	91.8%	
CO2 Chiller	%	73.8%	82.3%	81.8%	81.2%
Closest Approach Temperature (K)	(K)	10.7	18.0	21.1	18.0
CC Heat Rate (GT only=9611 BTU/kWh)	BTU/kWh	7323	7037	7012	6949
Effective Revenue from Elect Sales	\$M/year	2.168	2.339	2.456	2.473
Approx \$/kWe Net	\$/kWe	1717	2019	1890	1985
Net Elect. Power	kWe	7017	8214	8322	8601
Combined Cycle Total Efficiency	%	46.6%	48.5%	48.7%	49.1%
Total Capital Costs (FOAK)	M\$	12.047	16.581	15.729	17.070
Rate of Return	%	18.0%	14.1%	15.6%	14.5%

← WHR are Grouped Together

← Max TIT Higher for Pat. Cycles

← High Effectiveness for HXs



← Approach Temps 10 C – 21 C

← CC Heat Rate Near 7000 BTU/kWh

} See Bar Charts (Next)

Economic Performance Summary Chart for sCO₂ Bottoming Cycle (SRBC versus WHR-Cycles)



~1 MWe
Additional
Power



300 k\$/yr
Additional
Revenue

300 k\$/KWe
Additional
Capital Costs



CapX ~ 2 \$/We



3% points
Additional
Net
Efficiency
for sCO₂
Bottom
Cycle

Combined Cycle Economic Comparisons

	SRBC	Cascaded	Dual Recup	Preheating	Gas Turbine Only
LCOE at Fuel Costs of 3\$/MMBTU	\$0.0294	\$0.0291	\$0.0289	\$0.0289	\$0.0342
LCOE at Fuel 5\$/MMBTU	\$0.0416	\$0.0409	\$0.0406	\$0.0405	\$0.0502



Combined Cycle Capital Costs (\$0.750/We for Gas Turbine and \$2/We for sCO₂) = \$1.05/We
 Combined Cycle Efficiency Increases from 35.5% to 46-49%)
 LCOE Decreases from \$0.05/kWh to \$0.04/kWh (Well below Grid Price of Elect) (5\$/MM BTU of Nat Gas)

Conclusions

- **Conclusions for Combined Cycle**

- Combined Cycle Efficiency Increases from 35.5% to 46-49%
- With LCOE reduction of 1cent/kWh at \$5/MMBTU Natural Gas
- LCOE is well below market price of electricity in most markets
- Reduction of Heat Rating from 9611 BTU/kWh to ~7000 BTU/kWh

- **Conclusions for sCO₂ WHR Power Systems**

- All WHR systems perform about the same (both power and economics)
- All WHR cycles produce 1.2-1.6 MWe more compared to SRBC
- Annual Revenue for WHR sCO₂ increases \$200-300 k/yr (12-15% above SRBC)
- Capital costs increase from 12 M\$ to 16-17 M\$ (from 1.7 to ~ 2\$/We)
- HXs represent about 40-50% of total system cost
- Economic benefit to increasing HX Effectiveness to 93-95% range
- WHR Efficiency is 61% for SRBC and 75-85% for WHR systems

sCO₂ WHR Performance and Economic Benefits are Substantial

Key: A Business Model that Meets Customer's Needs

Expanding Markets, New Markets, Modularity, Power Independence, Grid Independence,
Grid Reliability, High Reliability, More Competitive Products