

Test Rig Design for Large Supercritical CO₂ Turbine Seals




Presented by:

Aaron Rimpel

Southwest Research Institute
San Antonio, TX

**The 6th International Supercritical CO₂
Power Cycles Symposium**
March 27-29, 2018, Pittsburgh, Pennsylvania



SOUTHWEST RESEARCH INSTITUTE MACHINERY PROGRAM
www.machinery.swri.org

Acknowledgements



Natalie Smith*
Jason Wilkes*
Hector Delgado*
Timothy Allison*
Jeff Moore



GE Global Research

Rahul Bidkar*
Uttara Kumar*
Deepak Trivedi*
Bugra Ertas
Jason Mortzheim
Chris Wolfe




Seth Lawson (Project Manager, DOE)
DOE Award Number DE-FE0024007

* Co-author



Utility-scale sCO₂ turbines require advanced seals

- Utility-scale ~ 450 MW_e
- Shaft end seal requirements
 - P_{high} ~ 75 bar
 - Diameter ~ 24 in.
- sCO₂ poses unique challenge for end seals compared to gas or steam turbines
- Film-riding face seals vs. labys **increase cycle efficiency 0.6-0.8 points**
- Seals at this size, pressure do not exist




Bidkar et al., 2016, "Conceptual Designs of 50 MW_e and 450 MW_e Supercritical CO₂ Turbomachinery Trains for Power Generation from Coal. Part 1: Cycle and Turbine," The 5th International Supercritical CO₂ Power Cycles Symposium, March 28-31, San Antonio, TX.

Current research developing large sCO₂ face seal

Current DOE project activities



- Detailed design of new face seal technology
- Reduced-size prototype testing
- **Detailed design of full-scale seal test rig**
- *Construction & commissioning of full-scale test rig (2018)*
- *Full-scale seal testing (2019)*



Bidkar et al., 2016, "Low-Leakage Shaft End Seals for Utility-Scale Supercritical CO₂ Turboexpanders," Paper No. GT2016-56979, ASME Turbo Expo 2016, June 13-17, Seoul, South Korea.

Test rig overview

- Back-to-back seal arrangement
- Thrust balanced
- Open- and closed-loop




Conditions:
75 bar, 400°F max
1-10 bar



Casing design limited by deflections

- Design by ASME BPVC, VIII-2
 - Linear elastic
 - **Elastic-plastic**
 - Cyclic loading (ratcheting)
- Stress design exceeds BPVC requirements
- Increased wall thickness to limit deflections to 0.0005”




Elastic-plastic analysis solution, thinner walls than current design


Multi-piece rotor concepts evaluated, not selected

- Perceived advantages of multi-piece rotor
 - Less wasteful material use assuming standard cylinder shapes
 - Replacement disk cheaper than entire rotor
 - Tie bolt concept lighter, more rigid than solid shaft (improved rotordynamics)
- Actual advantages of single-piece rotor
 - Simpler design
 - Near-net-shape forging cost reasonable
 - Less overall machining
 - Greater burst margin
 - Negligible difference in repair cost
 - Critical speed separation margin > 100%


Earlier multi-piece rotor concepts



Current: single piece rotor




Flow loop leverages existing sCO₂ facility





Flow loop design

- Less challenging than other sCO₂ projects due to lower temperature
- Upstream piping
 - 316 stainless steel
 - 3 micron filter
- Downstream piping
 - Carbon steel




Flow network analysis


- Quantify pressure drops
- Size piping
- Cases
 - Design conditions
 - Test seal failure
 - Maximum downstream pressure
 - Maximum ΔP / thrust force



Design case pressure drops




Seal failure without protection results in excessive downstream pressure and thrust force




- Simulated DE seal as no restriction (failure)
- Assume all valve settings at same set point
- Assume supply pressure from pump remains unchanged
- Allow flow rates to increase due to less restriction (conservative)

Mitigation approach utilizes PSVs and rupture disk

- PSVs protect downstream cavities from excessive pressure
 - 200 psi set point
 - Sized to handle flow of seal supply
- Rupture disk protects from excessive ΔP
- Check valve on return line prevents back flow into rig







Mitigation features ensure rig safety in seal failure



- Downstream pressures and ΔP acceptable
- Only PSV on failed seal side simulated – second PSV and rupture disk offer redundant protection
- Decrease in supply pressure due to increase in mass flow through CV-301

Summary & Conclusions

- Currently developing seal technology for utility-scale sCO₂ turbines
- Full-scale test rig detail design being completed
- Casing design limited by deflection control
- Single-piece rotor design more cost-effective, simpler
- Loop design considered seal failure scenario to limit downstream pressure, rotor thrust force



Thank you... Any questions?

Aaron Rimpel

Southwest Research Institute
San Antonio, TX

aaron.rimpel@swri.org



**The 6th International Supercritical CO₂
Power Cycles Symposium**

March 27-29, 2018, Pittsburgh, Pennsylvania

Disclaimer: This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Major flow elements (backup)

Tag	Parameter Description	Units	Design Case	Failure Scenario 1	Failure Scenario 2
Line A	Mass Flow (norm.)	-	1.000	1.053	1.588
	Supply Pressure	-	P _{supply}	P _{supply}	P _{supply}
CV-301	Mass Flow (norm.)	-	0.817	0.613	0.954
	Restriction Bore Diameter Ratio	-	0.315	0.315	0.315
CV-303	Mass Flow (norm.)	-	0.093	0.353	0.551
	Restriction Bore Diameter Ratio	-	0.472	0.472	0.472
CV-304	Mass Flow (norm.)	-	0.093	0.087	0.084
	Restriction Bore Diameter Ratio	-	0.472	0.472	0.472
Swirl Ring	Upstream Pressure	bar	83.0	101.0	51.0
	Downstream Pressure	bar	75.0	97.5	13.8
	K factor	-	1.86	1.86	1.86
Seal DE	Downstream Pressure	bar	10.0	97.5	13.8
	K factor	-	4.46	NA	NA
Seal NDE	Downstream Pressure	bar	10.0	17.3	16.8
	K factor	-	4.46	4.46	4.46
Line C DS	Mass Flow (norm.)	-	0.712	NA	NA
	Return Pressure	bar	70.0	NA	NA
CV-305	Mass Flow (norm.)	-	0.146	0.913	0.111
	Restriction Bore Diameter Ratio	-	0.165	0.165	0.165
CV-306	Mass Flow (norm.)	-	0.146	0.140	0.135
	Restriction Bore Diameter Ratio	-	0.165	0.165	0.165
Exit Tee	Pressure Match	-	ΔP = 0	ΔP = 0	ΔP = 0
Exit	Ambient Pressure	bar	1	1	1

