

The 7th International Supercritical CO<sub>2</sub> Power Cycles Symposium  
February 21 – 24, 2022, San Antonio, Texas  
Paper #120



**ECHOGEN**  
power systems

sCO<sub>2</sub> Primary Power Large-Scale Pilot Plant FEED Summary

## Fossil Fuel Large-Scale Pilots

*“transformational coal technologies aimed at enabling step change improvements in coal powered system performance, efficiency, and cost of electricity”*

- Phase I: Feasibility – completed March 2019
  - 9 projects
- Phase II: FEED – completed January 2021
  - 6 projects
    - sCO<sub>2</sub> (1 project)
    - Gasification (1 project)
    - Advanced combustion (1 project)
    - CO<sub>2</sub> capture (3 projects)
- Phase III: Construction/Operation – began June 2021
  - 2 projects
    - CO<sub>2</sub> capture (2 projects)





## Intended Outcomes of Three-Phase Program


- Prove sCO<sub>2</sub> Recompression Brayton Cycle (RCBC) at large pilot scale
  - Transformational efficiency improvements (2 to 8 points)
  - Range of potential commercial plant sizes (50 to 500 MWe)
  - Flexible heat source
    - Pilot – coal, biomass, natural gas
    - Technology – fossil, nuclear, CSP, biomass, waste heat recovery
- Operate sCO<sub>2</sub> system in power plant environment
  - Connection to grid
  - Duration testing at various loads and ramp rates
- Advance sCO<sub>2</sub> component technology
  - Solid-fuel fired heater (applicable to biomass as well as coal)
  - Parallel turbo-compressors (maximizing sCO<sub>2</sub> efficiency for primary power)
  - Multi-stage axial power turbine (maximizing turbine efficiency at commercial scale)

Technology at TRL 7 upon completion of pilot program



## Project Team



- Echogen Power Systems
  - Power cycle design and fabrication
  - Turbomachinery design and fabrication 
- Louis Perry and Associates, a CDM Smith Co.
  - EPC – FEED contractor
  - Balance of plant engineering and Phase III construction
- Electric Power Research Institute
  - Economic analysis
  - Test planning and Phase III test support
  - Industry voice
- University of Missouri
  - Host site
  - Permitting
  - Plant operations
- Riley Power
  - Coal-fired heater design and fabrication
  - Air quality control systems (AQCS) design and fabrication

# MU Combined Cooling Heat and Power (CCHP) Plant




## Plant Summary

- 66 MW electric power generation
- 1.1 MMlb/hr of steam
- Provides heat, power, and chilled water to MU campus

## Equipment


- 5 solid fuel boilers
- 1 package boiler
- 2 combustion gas turbines w/ HRSG
- 4 steam turbine generators
- Electric and steam chillers
- Cooling towers and wells




## MU CCHP Existing Boiler Building Layout




- Power plant located on MU college campus
- Boilers 7, 8, 9 to be removed and replaced with new CO<sub>2</sub> fired heater and power cycle equipment



# RCBC Configured with Turbine-driven Compressors




# RCBC Pressure-Enthalpy Diagram






# RCBC-E with an sCO<sub>2</sub> Economizer (PHX-2)



## sCO<sub>2</sub> Economizer Impact: Fired Heater Efficiency

### PHX Temperature Profiles




### Efficiency Impact

- Economizer (PHX-2) critical for overall plant efficiency with combustion byproduct as the thermal resource
- Added ~10% points to fired heater efficiency

# sCO<sub>2</sub> Economizer Impact: Power Cycle Efficiency

## HTR Impact




With rising PHX-2 duty...

→ HP CO<sub>2</sub> flow shifts from HTR to PHX-2

→ HTR: Higher  $\Delta T_{HP\ CO_2}$ , Lower  $\Delta T_{hot}$

→ HTR: Lower  $\Delta T_{LM,corr}$ , Higher UA


## Efficiency Impact




PHX-2 duty not large enough to penalize power cycle efficiency

## Process Overview – Fired Heater and sCO<sub>2</sub> Power Cycle

- **Power Cycle – 10 MW<sub>e</sub> nominal**
  - Modified Recompression Brayton Cycle:  $\eta = 39.4\%$  (gross), 35.3% (net)
  - Turb. Inlet Temp. = 600°C (1112°F)
  - Turb. Inlet Pres. = 23 MPa (>3300 psig)
- **Process Cooling**
  - Water cooled (existing system)
  - Cooling water temp. = 26°C
- **Fired Heater – 32 MW<sub>th</sub>**
  - Stoker style combustion:  $\eta = 84.3\%$
  - CO<sub>2</sub> cooled walls
- **Air Quality Control Systems**
  - Full AQCS scope including SCR (NO<sub>x</sub>), scrubber (SO<sub>2</sub>), and baghouse (PM)




# Fired Heater and AQCS



SCR = Selective Catalytic Reduction  
CDS = Circulating Dry Scrubber

## Fired Heater Design Highlights




- Fuel
  - Up to 100% Bituminous coal (Illinois #6)
    - HHV 11,338 Btu/lb
  - Up to 100% Natural gas
  - Up to 20% biomass
- Efficiency
  - 84.3% (90% coal / 10% natural gas)
  - 84.6% (100% coal)
  - Stoker technology limitations
    - High excess air (27-30%)
    - High unburned carbon loss (2%)
- CO<sub>2</sub> temperature control
  - Natural gas firing as temperature trim (limited enthalpy differential for attemperation)
- Sootblowers
  - CHP plant steam


## Heater Design – Primary Circuit and Economizer



- PHX required to combine
  - Turbine inlet temperature (TIT) comparable to steam-Rankine USC
  - CO<sub>2</sub> wall cooling
  - Solid fuel firing
  - Large pilot scale
- Features
  - Designed similarly to a traditional utility steam boiler (CO<sub>2</sub> is utilized for wall cooling)
  - Radiant furnace for combustion and final CO<sub>2</sub> heating (to 600°C)
  - Convection pass for initial CO<sub>2</sub> heating (three tube banks for CO<sub>2</sub> primary heating followed by one tube bank for CO<sub>2</sub> hot economizer)
  - Features a split economizer system for control of flue gas temperature entering the SCR




# CO2 Fired Heater Flow Path





## Design Pressure and Temperature



- Efficiency datum
  - PDP = 20 MPa
  - TIT = 500°C
- PDP
  - Diminishing returns above 25-26 MPa
  - LSP: 25 MPa (+10% for design pressure)
- TIT
  - $\geq 600^{\circ}\text{C}$  to compare with steam-Rankine USC
  - $\geq 600^{\circ}\text{C}$  reduced allowable stress for SS (or step change cost change for nickel alloy)
  - LSP:  $600^{\circ}\text{C}$  (+10°C for design temperature)



## FEED Performance Predictions

---

Description	Initial Value (FEED Basis)	Final Value (FEED Results)
Fired heater (%)	86.0	84.3
Power cycle, gross (%)	40.6	40.0
Power cycle, net (%)	37.0	35.8
Overall plant (%)	31.8	30.2



## Acknowledgements

- This material is based upon work supported by the Department of Energy under Award Number DE-FE0031585.
- This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.