

# Modeling and Economic Analysis of sCO<sub>2</sub> Power Systems Hybridized with a Gas Turbine

APPLIED  
SOUTHWEST RESEARCH INSTITUTE®

February 27, 2024

Joshua Schmitt  
Assistant Program Manager


# Motivation

- Explore the hypothesis of cost and performance efficiency for Gas turbines in combined cycle with SCO<sub>2</sub>
- Ground the assessment with existing turbines and limiting SCO<sub>2</sub> components/complexity
- Microgrid (20-30 MW) scale
  - Apply to systems like the SwRI campus
  - Load following and operates off-design
- Utility (about 1 GW) scale
  - Compare to DOE baselines
  - Operates as a on-design baseload with a 15% downtime through the year

# Approach

- Pick a gas turbine generator as a consistent size and build an SCO<sub>2</sub> cycle that uses the waste heat from the combustion turbine
- Model in Aspen Plus with REFPROP properties
- Use literature sources for combustion turbine performance and waste hot gas flow rate/composition
  - NETL baseline for utility-scale H-Class gas turbine combined cycle (GTCC)
  - NETL indirect SCO<sub>2</sub> baseline also used to assess cost/performance of SCO<sub>2</sub> cycles
  - EPA Study of small combustion turbines for the small system case
- Seek to maximize heat from gas turbine exhaust heat and minimize pinches in heat exchangers

# Dual Cascaded (DC) Cycle




Combustion Turbine Gas

High Pressure SCO<sub>2</sub>

Low Pressure SCO<sub>2</sub>

# Preheat, Recuperation, Overheat (PRO) Cycle



Combustion Turbine Gas

High Pressure CO<sub>2</sub>

Low Pressure CO<sub>2</sub>

# System Design Assumptions


- 15°C approach temperature in waste heat recovery exchanger
- 10°C approach temperature in recuperators and coolers
- Ambient temperature is 25°C
- SCO<sub>2</sub> turbines are 90% isentropic efficiency
- SCO<sub>2</sub> compressors are 80% isentropic efficiency
- 85 bar as the compressor inlet pressure
- Different compressor outlet pressures due to exchanger tuning
  - DC cycle: 300 bar
  - PRO cycle: 380 bar

# Performance Results

- Fixed GT capacity for the different scales
  - Small GT exhaust: 586°C
  - Large GT exhaust: 596°C
- In DC cycle the SCO2 system capacity is around half the size of the GT
- In PRO cycle the SCO2 system capacity is similar to the GT size
  - Note that PRO cycle efficiency shown is for standalone operation

	Small GT with DC Cycle	Small GT with PRO Cycle	H-Class GT with DC Cycle	H-Class GT with PRO Cycle
GT Efficiency (%)	39.1%	39.1%	43.8%	43.8%
GT Output Size (kW)	13,962	13,962	685,495	685,495
SCO2 Efficiency (%)	31.9%	39.1%*	32.4%	39.2%*
SCO2 Output Size (kW)	5,890	15,074	252,139	603,320
System Total Output Size (kW)	19,852	29,036	937,634	1,288,815
Combined System LHV Thermal Efficiency (%)	55.6%	52.4%	59.8%	55.0%
*Note that the SCO2 PRO cycle efficiency is in standalone operation assuming heat through the WHR-EX is provided externally and not by the GT exhaust				


# DC Cycle Waste Heat Exchanger Profile (H-Class)



- 15°C approach at Hot end with 18°C difference on cold
- Small GT: cold end difference is 37 °C




# DC Cycle High Temperature Recuperator (H-Class)



- 10°C approach at Hot end with 12°C difference on cold
- Small GT: Hot inlet is lower at 421°C with a 14°C difference on cold


# DC Cycle Low Temperature Recuperator (H-Class)

Block LTR: TQ Curves



- 10°C approach at Hot end with 11°C difference on cold
- Small GT: Hot inlet is lower at 273°C with a 13°C difference on cold
- CO2 Cooler Inlet Temperatures: 102°C and 101°C for large GT and small GT


# PRO Cycle Waste Heat Exchanger Profile (H-Class)



- 15°C approach at Hot end with 18°C difference on cold
- Small GT: cold end difference is 37°C

# PRO Cycle Recuperator (H-Class)



Block HTR: TQ Curves



- 10°C approach at Hot end with 55°C difference on cold
- Small GT: Similar profile
- Entering cooler at 150°C


# Target Application

- Utility Scale
  - Match NETL baseline profile
  - Baseload with constant power output at full capacity
- Microgrid Scale
  - Used a representative profile, SwRI campus electric load
  - Higher peaks in summer and work days
  - Scaled max power in the profile to match the overall system maximum power output



# Off-Design

- Off-design needed for microgrid load-following operation
- Profile adopted from literature and scaled to on-design efficiency
- Future work will build an off-design curve from sized equipment in Aspen Plus
  - Will feed into a more detailed economic estimate



# Techno-Economic Assessment Inputs

- System costs built from literature on total installed cost
  - Sources that detail the cost by component
  - Components that were not present were removed, such as a recompressor
- EPC costs based on baselines at 20%
- 30 year system with 20 year payback with 71.8% financed at 5% fixed rate
- Natural gas cost of \$ 4.64  $\$/GJ_{LHV}$
- LCOE follows discounted cash flows
  - 2.5% inflation
  - 5.1% real discount rate

	Small GT with DC Cycle	Small GT with PRO Cycle	H-Class GT with DC Cycle	H-Class GT with PRO Cycle
GT System Capacity Cost ( $\$/kW_{AC}$ )	1,510	1,510	771	771
SCO2 System Capacity Cost ( $\$/kW_{AC}$ )	2,900	2,900	2,130	2,087
Combined Capacity Cost ( $\$/kW_{AC}$ )	1,946	2,232	1,137	1,388

GT Fixed OPEX	26	$\$/kW$
GT Variable OPEX	1.2	$\$/MWh$
SCO2 Fixed OPEX	113	$\$/kW$
SCO2 Variable OPEX	4.4	$\$/MWh$


# Cost Results for Systems

	Small GT with DC Cycle	Small GT with PRO Cycle	H-Class GT with DC Cycle	H-Class GT with PRO Cycle
CAPEX GT System	\$21.1 M	\$21.1 M	\$528.8 M	\$528.8 M
CAPEX SCO2 System	\$17.1 M	\$43.7 M	\$537.1 M	\$1,259.4 M
CAPEX Combined System	\$38.2 M	\$64.8 M	\$1,066.0 M	\$1,788.3 M
EPC and Owner's Costs	\$7.6 M	\$13.0 M	\$213.2 M	\$357.7 M
<b>Total CAPEX</b>	<b>\$45.8 M</b>	<b>\$77.8 M</b>	<b>\$1,279.2 M</b>	<b>\$2,145.9 M</b>
OPEX GT System	\$0.5 M	\$0.6 M	\$26.2 M	\$29.3 M
OPEX SCO2 System	\$1.2 M	\$2.4 M	\$59.2 M	\$110.4 M
<b>Total OPEX</b>	<b>\$1.6 M</b>	<b>\$3.0 M</b>	<b>\$85.4 M</b>	<b>\$139.7 M</b>
Annual Payment for 20-year Financing	\$2.6 M	\$6.7 M	\$195.1 M	\$291.6 M
Capacity Factor (%)	63.4%	63.4%	85%	85%
Power Exports (MWh)	110,301	161,330	6,981,623	9,596,516
Natural Gas Imports (tonne <sub>NG</sub> )	19,821	30,761	890,444	1,330,768
Annual Fuel Cost (\$)	<b>\$4.3 M</b>	<b>\$6.7 M</b>	<b>\$195.1 M</b>	<b>\$291.6 M</b>



# Levelized Cost of Electricity

- Initial estimate of LCOE breakdown
  - Not mature enough to match DOE baseline level of detail
- The DOE baseline LCOE
  - Coal SCO<sub>2</sub>: \$123-128/MWh
  - H-Class CCGT \$42.7/MWh
- Future work will refine the system design, performance estimate, CAPEX, and OPEX



# Conclusions

- Initial assessment of two different combined cycle configurations each at two different scales
- Applied initial performance results to profiles for the specific applications
  - Load following system in a representative microgrid
  - Baseload utility scale with 85% capacity factor
- All systems were above 55% in cycle efficiency
- Initial estimate of cost and LCOE was assessed based on simple scaling parameters
  - Microgrid LCOE is \$65-73/MWh
  - Utility LCOE is \$41-47/MWh
- Further work is needed to more closely match baseline methods and refine costs and LCOE estimates

# Thank You