



Techno-economic Analysis of an Energy Storage System Utilizing the STEP Facility

Owen M. Pryor, Ph.D., Joshua M. Schmitt, Timothy C. Allison, Ph.D.

Southwest Research Institute

Paper - 076

2026 International sCO₂ Energy Technologies Symposium

March 4, 2026

Pittsburgh, PA



Outline


Background & Motivation

- The SwRI Microgrid
- PyZ Modeling Tool
- STEP Facility?
- PyZ Modeling Tool

Background & Motivation


Micro-grids are small independent or semi-independent grids

- Only around 4.4 GW (0.3%) of installed capacity in US
- Often located in remote or rural areas
- Historically, dominated by fossil-fired systems




SwRI is a unique corporation to explore the energy transition


- Significant load required
- Large seasonal, diurnal and weekly load variations
- Privately owned with a significant amount of land available



20-22 MW peak load in Summer




PyZ was created in Python to serve as a modular tool for analyzing micro-grids



PyZ utilizes established models for renewable energy

- PVWatts 8 (SAM)
- WindPower (SAM)
- National Solar Radiation Database (NSRDB)
- Wind Resource Database (WRDB)



Average Solar Irradiance in Continental U.S.

PyZ modules have been validated against NREL baselines

Location: Fredonia, KS

Key Assumptions

Parameter	Commercial PV (Rooftop, 200 kWDC)	Utility-Scale PV (One-Axis Tracking, 100 MWDC)
Installed cost (\$/WDC)	1.63	0.87
Annual degradation (%)	0.7	0.7
Levelized O&M expenses over life of asset (\$/WDC-yr)	18	16
Preinverter derate (%)	85.9	85.9
Inverter efficiency (%)	96	96
tilt/azimuth	10/190	tracking/180
Array Type	Fixed Roof Mount	1-axis backtracking

Model Outputs

Parameter	Commercial PV (Rooftop, 200 kWdc)		Utility-Scale PV (One-Axis Tracking, 100 MWdc)	
	NREL Baseline	Model Result	NREL Baseline	Model Result
MSP Installation Cost [\$/W]	1.63	1.64	0.87	0.87
MMP Installation Cost [\$/W]	1.84	1.85	0.99	0.99
Energy Yield [kWh/kW]	1398	1395	1694	1684
MSP LCOE Levelized cost of energy real [¢/kWh]	8.70	8.83	4.10	4.10
MMP LCOE Levelized cost of energy real [¢/kWh]	N/A	9.75	N/A	4.50

Ramasamy, V., Zuboy, J., O'Shaughnessy, E., Feldman, D., Desai, J., Woodhouse, M., Basore, P., and Margolis, M., "U.S. Solar Photovoltaic System and Energy Storage Cost Benchmarks, with Minimum Sustainable Price Analysis: Q1 2022", National Renewable Energy Laboratory, Golden, CO, September, 2022, NREL/TP-7A40-83586.



The STEP Facility is the 1st Multi-MW sCO₂ Power Plant

- Designed to provide up to 10 MW to the SwRI grid
- SwRI and GTI produced 4 MW-net in the Fall of 2024



Microgrid Modeling & Key Assumptions

SwRI would struggle to penetrate more than 50% of their electricity with PV alone



PV System Key Assumptions

- The PV field was swept between 0-100 MW

Parameter	Value
Location for Solar Resource	San Antonio, TX
Ground Coverage Ratio	0.4
Tilt [°]	0
Azimuth Angle [°]	180
Pre-inverter DC Losses [%]	14.1
Inverter Efficiency [%]	96
Inverter Loading Ratio [-]	1.1
Array Type	1-axis-backtracking
Degradation [%/yr]	0.7
PV CAPEX [2024\$/kW]	961.40
PV OPEX [2024\$/kW]	16



Storage and Utility Assumptions

- The storage system was swept between 0-50 MWh
- The charge duration was set to 6 hours
- The discharge duration was set to 10 hours

Parameter	Value
Storage CAPEX [2024\$/kW _{th}]	126.56
Storage CAPEX [2024\$/kW _{th}]	126.56
Storage OPEX [2024\$/kW]	0
Charge CAPEX [2024\$/kW]	934.52
Charge OPEX [2024\$/kW]	26.85
Discharge CAPEX [2024\$/kW]	597.48
Discharge OPEX [2024\$/kW]	26.85

Parameter	Value
Utility Energy Charge [\$/kWh]	0.066
Utility Demand Charge (Summer Season) [\$/kW]	14.37
Utility Demand Charge (non-Summer Season) [\$/kW]	9.36
Investment Tax Credit [%]	30
Real Discount Rate [%]	4.74
Inflation Rate [%]	2.5
Load Escalation Rate [%]	2.0


Storage would increase grid penetration but reduce the savings



Demo System with STEP


STEP Microgrid Model

- PV system was varied between 0-100 MW
- The storage system was swept between 100 MWh
- The charge duration was set to 6 hours
- The discharge duration was set to 10 hours





STEP system was modeled using actual test data

- Efficiency for the STEP facility was varied based on data from the Simple Cycle Configuration Test Campaign
 - $3.7 \text{ MW}_{\text{el}}$
 - $10 \text{ MW}_{\text{heat}}$



The energy storage system would reduce savings significantly but would improve emissions starting with at least 15 MW PV



Conclusions

- SwRI needs energy storage to produce more than 46% of its electricity
- Converting STEP to an energy Storage system would cost at least \$34MM
- SwRI could reduce carbon intensity to 0.234 kg/kWh using the STEP facility and a 40 MW PV field
- The facility would take around 14 years to payback

Questions